



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Lake House
The Green, Lake Walk
Adderbury, Banbury
Oxford OX17 3NG

Customer: The Orders of St. John Care Trust

Date: 16 October 2012

System Type and Location: Cold Water Storage Tank 1 – Orchid Wing Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Lake House
The Green, Lake Walk
Adderbury, Banbury
Oxford OX17 3NG

Customer: The Orders of St. John Care Trust

Date: 16 October 2012

System Type and Location: Cold Water Storage Tank 2 – Fuchsia Wing Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Lake House
The Green, Lake Walk
Adderbury, Banbury
Oxford OX17 3NG

Customer: The Orders of St. John Care Trust

Date: 16 October 2012

System Type and Location: Cold Water Storage Tank 3 – Laurel Wing Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Lake House
The Green, Lake Walk
Adderbury, Banbury
Oxford OX17 3NG

Customer: The Orders of St. John Care Trust

Date: 16 October 2012

System Type and Location: Cold Water Storage Tank 4 – Jasmine Wing Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = as mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



Freston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freston.co.uk
Web: www.freston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Lake House
The Green, Lake Walk
Adderbury, Banbury
Oxford OX17 3NG

Customer: The Orders of St. John Care Trust

Date: 16 October 2012

System Type and Location: Cold Water Storage Tank 5 – Heather Wing Roof Space

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = as mains

Scope of Work Completed: ACoP L8

Freston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freston.co.uk



LEGIONELLA
CONTROL ASSOCIATION