



Certificate of Analysis

Freeston Water Treatment Ltd
 Unit 1, Lulworth Business Centre
 Nutwood Way
 Calmore Industrial Estate
 Southampton
 SO40 3WW

Sample Date: 08-Dec-11
 Received Date: 08-Dec-11
 Test Date : 09-Dec-11
 Certificate Ref: 65218-21/12/2011 09:16:15 (4)
 Certificate ID: 194340
 Order Number: CH0145/148
 SDG Reference: FWT_SOU 08-12-11 4
 Laboratory Reference: FWT_SOU[LY]336174
 Legionella Process Date: 09/12/2011

Sample : CH0148

Details : CH0148

Method Ref	Determination	Result	Units
BP50.9	Legionella spp.	1800	cfu/l
BP50.9	Legionella spp.	900	cfu/Volume
BP50.9	Legionella pneumophila SG 1	Not Detected	cfu/Volume
BP50.9	Legionella pneumophila SG 1	N/A	cfu/l
BP50.9	Legionella pneumophila SG 2-14	Not Detected	cfu/Volume
BP50.9	Legionella pneumophila SG 2-14	N/A	cfu/l
*	Volume Of Sample Filtered	500	ml

Approved By: Agnieszka Dassuj(Senior Analyst)

Date: 20-Dec-11

Page 1 of 1

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by RM = Rotherham, DB = Dublin, BH = Bellshill, which comprise the 0996 group. Method suffix denotes testing laboratory. Tests marked *, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996. Those marked: * have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996