



Certificate of Analysis

Freeston Water Treatment Ltd
Unit 1, Lulworth Business Centre
Nutwood Way
Calmore Industrial Estate
Southampton
SO40 3WW

Sample Date: 26-Jan-12
Received Date: 26-Jan-12
Test Date : 27-Jan-12
Certificate Ref: 75110-08/02/2012 14:18:15 (4)
Certificate ID: 231019
Order Number: CHO179/185
SDG Reference: FWT_SOU 26-01-12 1
Laboratory Reference: FWT_SOU[LY]392149
Legionella Process Date: 27/01/2012

Sample : CHO182

Details : CHO182

Method Ref	Determination	Result	Units
BP50.9	Legionella spp.	N/A	cfu/l
BP50.9	Legionella spp.	Not Detected	cfu/Volume
*	Volume Of Sample Filtered	500	ml

Approved By: Grainne McNeece(Lab Manager)

Date: 07-Feb-12

Page 1 of 1

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by RM = Rotherham, DB = Dublin, BH = Bellshill, which comprise the 0996 group. Method suffix denotes testing laboratory. Tests marked *, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996. Those marked: * have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996