



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Townsend House  
Bayswater Road  
Headington  
Oxfordshire OX3 9NX

**Customer:** The Orders of St. John Care Trust

**Date:** 10<sup>th</sup> December 2012

**System Type and Location:** Cold Water Storage Tank 1 (Main) – Roof Space

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Chemical level @ Start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeton Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeton.co.uk](mailto:info@freeton.co.uk)  
Web: [www.freeton.co.uk](http://www.freeton.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Townsend House  
Bayswater Road  
Headington  
Oxfordshire OX3 9NX

**Customer:** The Orders of St. John Care Trust

**Date:** 10<sup>th</sup> December 2012

**System Type and Location:** Cold Water Storage Tank 2 – Roof Space

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Chemical level @ Start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeton Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeton.co.uk](http://www.freeton.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeton Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeton.co.uk](mailto:info@freeton.co.uk)  
Web: [www.freeton.co.uk](http://www.freeton.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Townsend House  
Bayswater Road  
Headington  
Oxfordshire OX3 9NX

**Customer:** The Orders of St. John Care Trust

**Date:** 10<sup>th</sup> December 2012

**System Type and Location:** Cold Water Storage Tank 3 (Blue) – Roof Space

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Chemical level @ Start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeton Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeton.co.uk](http://www.freeton.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeton Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeton.co.uk](mailto:info@freeton.co.uk)  
Web: [www.freeton.co.uk](http://www.freeton.co.uk)

## CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Townsend House  
Bayswater Road  
Headington  
Oxfordshire OX3 9NX

**Customer:** The Orders of St. John Care Trust

**Date:** 10<sup>th</sup> December 2012

**System Type and Location:** Cold Water Storage Tank 4 (Blue) – Roof Space

**Disinfecting Product:** Chlorine Dioxide

**Contact Time:** Chemical level @ Start  $\geq$  500ppm  
Chemical level @ 10 minutes  $\geq$  500ppm  
Chemical level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeton Water Treatment Limited

.....  
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

[www.freeton.co.uk](http://www.freeton.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION