



Aspen Court Laboratory, 7 & 8 Aspen Court, Bessemer Way, Rotherham, S60 1FB (UKAS Lab Nos. 0996 & 2300)
 Langley Laboratory, Heron Drive, Langley, Slough. SL3 8XP (UKAS Lab No. 0996)
 Bellshill Laboratory, Strathclyde Business Park, 2 Mallard Way, Bellshill ML4 3BF
 Dublin Laboratory, Unit 18A, Rosemount Business Park, Ballycoolin, Dublin 11, (UKAS Lab No. 0996)
 Telephone: 01709 777333 Fax: 01709 369639 E-mail: customer.services@alcontrol.com

Certificate of Analysis

Freeston Water Treatment Ltd

Sample Date : 16/11/2010

Unit 1, Lulworth Business Centre

Sample Received : 16/11/2010

Nutwood Way

Analysis Completed : 29/11/2010

Calmore Industrial Estate

SO40 3WW

Batch Number : 5778007

CH0036

Laboratory Number : 40935490

CH0035/36

Method	Determination	Result	Units
LBP50.9	Legionella SPP	Not Detected	CFU/Volume
LBP50.9	L.p. serogroup 1	Not Detected	CFU/Volume
LBP50.9	L.p. serogroup 2 to 14	Not Detected	CFU/Volume
*	Calc Legionella cfu/L	Not Detected	CFU/l
	Legionella Process Date	17/11/2010	
	Sample volume	0.50	Litres

Approved By

Phil Slater (Operations Manager)

03/12/2010

Page 1 of 1

Tests marked \$ in this report are subcontracted. Method prefix denotes the Lab where the analysis has been performed, B & R = Aspen Court Rotherham, L = Langley, S = Bellshill, D = Dublin. Tests marked * are not included in the UKAS Accreditation Schedule for our laboratory. Sampling, opinions and interpretations expressed are outside the scope of UKAS Accreditation. Method details are available on request. < = Less than, > = greater than. For taste and odour: 1 = present, 0 = absent. # = Data supplied by client. For softened water supply minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). TVC results >300 and coliform, E. coli, Enterococci, Clostridia, Pseudomonas and Staphylococcus >100 are regarded as estimates unless a dilution has been carried out.

