



Certificate of Analysis

Freeston Water Treatment Ltd
 Unit 1, Lulworth Business Centre
 Nutwood Way
 Calmore Industrial Estate
 Southampton
 SO40 3WW

Sample Date: 10-Nov-11
 Received Date: 10-Nov-11
 Test Date : 11-Nov-11
 Certificate Ref: 58475-24/11/2011 09:46:54 (1)
 Certificate ID: 175146
 Order Number: CH0142/144
 SDG Reference: FWT_SOU 10-11-11 1
 Laboratory Reference: FWT_SOU[LY]298188
 Legionella Process Date: 11/11/2011

Sample : CHO142

Method Ref	Determination	Result	Units
BP50.9	Legionella spp.	Not Detected	cfu/Volume
BP50.9	Legionella spp.	N/A	cfu/l
*	Volume Of Sample Filtered	500	ml

Approved By: Grainne McNeece(Lab Manager)

Date: 23-Nov-11

Page 1 of 1

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by RM = Rotherham, DB = Dublin, BH = Bellshill, which comprise the 0996 group. Method suffix denotes testing laboratory. Tests marked *, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996. Those marked: * have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996