



# Certificate of Analysis

Freeston Water Treatment Ltd  
Unit 1, Lulworth Business Centre  
Nutwood Way  
Calmore Industrial Estate  
Southampton  
SO40 3WW

Sample Date: 19-Jul-12  
Received Date: 20-Jul-12  
Test Date : 20-Jul-12  
Certificate Ref: 114167-30/07/2012 13:19:17  
(1)  
Certificate ID: 364815  
Order Number: CH0261/263  
SDG Reference: FWT\_SOU 20-07-12 2  
Laboratory Reference: FWT\_SOU[RM]607338  
Legionella Process Date: 20/07/2012

Sample : CH0261

Method Ref	Determination	Result	Units
*BP50.9	Legionella spp. (Calculated)	N/A	cfu/l
BP50.9	Legionella spp.	Not Detected	cfu/Volume
*	Volume Of Sample Filtered	500	ml

Approved By: Nasir Maroof(Senior Analyst)

Date: 30-Jul-12

Page 1 of 1

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by BH = Bellshill, which comprise the 0996 group. Method suffix denotes testing laboratory. Tests marked \*, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996. Those marked: \* have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. The Legionella (calculated) det is a calculated det where the result is extrapolated from the Legionella test results. A N/A result for Legionella (calculated) indicates a calculation cannot be performed as Legionella was not detected. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996