



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with BS 8558:2011

Site: Westgate House
Millington Road
Wallingford
OX10 8FE

Customer: Orders of St Johns Care Trust
Date: 31 January 2013

System Type and Location: Manifold 4 Nightingale wing roof space to cold water taps in day centre sluice & cleaners cupboard

Disinfecting Product: Chlorine Dioxide Solution
Chlorine Level of Source Water: <0.5 mg/l
Contact Time: Chlorine Level @ Start \geq 50ppm
Chlorine Level @ 30 minutes \geq 50ppm
Chlorine Level @ 1 hour \geq 50ppm

Chlorine Residual on Completion: <0.5 mg/l
Appearance: Clear
Taste & Odour: None
Scope of Work Completed: System/s disinfected and flushed to BS 8558:2011 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with BS 8558:2011

Site: Westgate House
Millington Road
Wallingford
OX10 8FE

Customer: Orders of St Johns Care Trust
Date: 31 January 2013

System Type and Location: Manifold 5 Nightingale wing roof space to hot water taps in day centre sluice & cleaners cupboard

Disinfecting Product: Chlorine Dioxide Solution
Chlorine Level of Source Water: <0.5 mg/l
Contact Time: Chlorine Level @ Start \geq 50ppm
Chlorine Level @ 30 minutes \geq 50ppm
Chlorine Level @ 1 hour \geq 50ppm

Chlorine Residual on Completion: <0.5 mg/l
Appearance: Clear
Taste & Odour: None
Scope of Work Completed: System/s disinfected and flushed to BS 8558:2011 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with BS 8558:2011

Site: Westgate House
Millington Road
Wallingford
OX10 8FE

Customer: Orders of St Johns Care Trust
Date: 31 January 2013

System Type and Location: Manifold 9 Nightingale wing roof space to hot water taps in Nightingale sluice

Disinfecting Product: Chlorine Dioxide Solution
Chlorine Level of Source Water: <0.5 mg/l
Contact Time: Chlorine Level @ Start \geq 50ppm
Chlorine Level @ 30 minutes \geq 50ppm
Chlorine Level @ 1 hour \geq 50ppm

Chlorine Residual on Completion: <0.5 mg/l
Appearance: Clear
Taste & Odour: None
Scope of Work Completed: System/s disinfected and flushed to BS 8558:2011 specification

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION