



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF DISINFECTION

This is to certify that the following water services have been disinfected in accordance with BS 8558:2011

Site: Westgate House
Millington Road
Wallingford
OX10 8FE

Customer: Orders of St Johns Care Trust
Date: 05 December 2012

System Type and Location: Incoming mains to day centre – sluice, staff WC's, bathroom, male & female WC's, rooms 9 -12 & day centre kitchen

Disinfecting Product: Sodium Hypochlorite Solution
Chlorine Level of Source Water: <0.5 mg/l
Contact Time: Chlorine Level @ Start \geq 50ppm
Chlorine Level @ 30 minutes \geq 50ppm
Chlorine Level @ 1 hour \geq 50ppm

Chlorine Residual on Completion: <0.5 mg/l
Appearance: Clear
Taste & Odour: None
Scope of Work Completed: System/s disinfected and flushed to BS 8558:2011 specification

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION