



Certificate of Analysis

Freeston Water Treatment Ltd
Unit 1, Lulworth Business Centre
Nutwood Way
Calmore Industrial Estate
Southampton
SO40 3WW

Sample Date: 11-Apr-11
Received Date: 13-Apr-11
Test Date : 14-Apr-11
Certificate Ref: 3924-28/04/2011 11:21:56 (3)
Certificate ID: 13893
Order Number: CH0076/77
SDG Reference: FWT_SOU 13-04-11 1
Laboratory Reference: FWT_SOU[LY]26317
Legionella Process Date: 14/04/2011

Sample : NV3250

| Method Ref | Determination | Result | Units |
|------------|---------------------------|--------------|------------|
| BP50.9 | Legionella spp. | Not Detected | cfu/Volume |
| BP50.9 | Legionella spp. | Not Detected | cfu/l |
| * | Volume Of Sample Filtered | 500 | ml |

Approved By: Phil Slater(Lab Manager)

Date: 27-Apr-11

Page 1 of 1

Abbreviations: < = Less than, > = Greater than. SDG = Sample Delivery Group. The site of test is identified by RM = Rotherham, DB = Dublin, BH = Bellshill, which comprise the 0996 and 2300 groups. Method suffix denotes testing laboratory. Tests marked *, # or \$ in this report are not included in the ISO 17025 accreditation schedule for the UKAS testing laboratories 0996 and 2300. Those marked: * have not been subcontracted and are not accredited; # have been subcontracted and are ISO 17025 Accredited; \$ have been subcontracted and are not ISO 17025 accredited; Comments, opinions and interpretations expressed herein are outside the scope of our UKAS accreditation. For softened water supply, minimum concentrations apply for hardness (60mg/l as Ca) and alkalinity (30mg/l as HCO3). Method details and performance characteristics are available on request. Results identified by ~ have been estimated (counts on plates were outside statistical limits).



0996