
TEST REPORT

Sender: Freston Water Treatment
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton SO40 3WW

Date Collected: 11/11/2013
Date Received: 12/11/2013
Sample Details: **Legionella**

<u>Senders Reference</u>	<u>Test</u>	<u>Results</u>	<u>Units</u>
Nightingale Sluice Sink Hot	Legionella spp	Not Detected	cfu/l
	Legionella pneumophila SG1	Not Detected	cfu/l
	Legionella pneumophila SG 2 – 14	Not Detected	cfu/l
Skylark Sluice Cold	Legionella spp	Not Detected	cfu/l
	Legionella pneumophila SG1	Not Detected	cfu/l
	Legionella pneumophila SG 2 – 14	Not Detected	cfu/l
Day Centre Cleaner Sink Hot	Legionella spp	100	cfu/l
	Legionella pneumophila SG1	100	cfu/l
	Legionella pneumophila SG 2 – 14	Not Detected	cfu/l
Day Centre Cleaner Sink Hot	Legionella spp	300	cfu/l
	Legionella pneumophila SG1	300	cfu/l
	Legionella pneumophila SG 2 – 14	Not Detected	cfu/l
Day Centre Kitchen Sink Cold	Legionella spp	100	cfu/l
	Legionella pneumophila SG1	100	cfu/l
	Legionella pneumophila SG 2 – 14	Not Detected	cfu/l

The above analysis has been carried out for Freston Water Treatment Limited by an Independent UKAS Accredited Laboratory (Reg. No. 0996)

DATE PRINTED: 25th November 2013
