



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Westgate House
Millington Road
Willingford
Oxfordshire

Customer: The Orders of St. John Care Trust

Date: 2nd January 2013

System Type and Location: Cold Water Storage Tank 1 – Above Room 15

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ Start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Westgate House
Millington Road
Willingford
Oxfordshire

Customer: The Orders of St. John Care Trust

Date: 2nd January 2013

System Type and Location: Cold Water Storage Tank 2 – Loft Hatch Above Room 15

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ Start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Westgate House
Millington Road
Willingford
Oxfordshire

Customer: The Orders of St. John Care Trust

Date: 2nd January 2013

System Type and Location: Cold Water Storage Tank 3 – Loft Hatch above Room 12

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ Start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freston.co.uk
Web: www.freston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Westgate House
Millington Road
Willingford
Oxfordshire

Customer: The Orders of St. John Care Trust

Date: 2nd January 2013

System Type and Location: Cold Water Storage Tank 4 – Loft Hatch above Room 12

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ Start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Westgate House
Millington Road
Willingford
Oxfordshire

Customer: The Orders of St. John Care Trust

Date: 2nd January 2013

System Type and Location: Cold Water Storage Tank 5 – Loft Hatch above Sluice in
Nightingale Wing

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ Start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING & DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Westgate House
Millington Road
Willingford
Oxfordshire

Customer: The Orders of St. John Care Trust

Date: 2nd January 2013

System Type and Location: Cold Water Storage Tank 6 – Loft Hatch above Sluice in
Nightingale Wing

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical level @ Start \geq 500ppm
Chemical level @ 10 minutes \geq 500ppm
Chemical level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION