

Customer name	<input type="text" value="OSJCT Willowcroft"/>	Purchase order No.	<input type="text" value="Contract 2013 - 2014"/>
Site Address	<input type="text" value="Odstock Road, Salisbury SP2 8BJ"/>	Date	<input type="text" value="08/10/13"/>
Telephone No.	<input type="text" value="01722323477"/>	Engineer	<input type="text" value="Adrian Wyatt"/>

**Scope of Work:**  
BS8580:2011 / ACoP L8

<input type="checkbox"/> 1 hour at 50 ppm free chlorine	<input type="checkbox"/> Sodium Hypochlorite
<input checked="" type="checkbox"/> 500ppm 10 minutes	<input checked="" type="checkbox"/> Chlorine Dioxide
<input type="checkbox"/> 150ppm	<input type="checkbox"/> Sanosil Super 25

Tank I.D	<input type="text" value="Tank 2"/>		
Screen Tank Vent	<input type="text" value="Yes"/>	Insect Screen on Overflow & Clear of Debris	<input type="text" value="Yes"/>
		Lid/s Fully Secure	<input type="text" value="Yes"/>
Adequate Tank Insulation	<input type="text" value="Yes"/>	Stagnation or Biofilm Present	<input type="text" value="No"/>
Tank Water Temperature °C	<input type="text" value="18"/>	Mains Inlet Temperature °C	<input type="text" value="16"/>
Comments	<input type="text" value="Tank 2 some stainage"/>		

### Chemical Levels & Contact Time

pH Level	<input type="text" value="7"/>	Chemical level at start (ppm)	<input type="text" value="500"/>	Chemical level at (minutes)	<input type="text" value="10"/>	Chemical level (ppm)	<input type="text" value="500"/>	Chemical level at finish (ppm)	<input type="text" value="As Main"/>
Location	<input type="text" value="Roof Space"/>		Size (metric)	<input type="text" value="4x3x2"/>					
Material of Construction	<input type="text" value="Steel Rubber lined"/>								