

**Portswood Library**  
**Review Photographs**  
**30<sup>th</sup> August 2017**



## Local Water Heater

The kitchen water heater was turned off at the time of this 2017 review; records seen indicated that the storage temperature is normally satisfactory.



## Toilet Water Heater

The toilet water heater still produces a vast amount of aerosols when turned on; staff informed me this water heater is normally not used due to the aerosol's being created and mess it makes when operational. Consider removal or replacement as it will create a deadleg if not used.



## **Toilet Water Heater Spray Nozzle**

The spray nozzle outlet on the water heater is in need of descaling to reduce the amount of aerosol creation when heater is in use.



## Insulation

The basement mains water pipe work has been insulated to help prevent heat gain and pipe work freezing; the basement infrequently used tap outlet has now been removed along with all associated pipe work.