



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: Weston Shore Infants School
Foxcott Close
Southampton SO19 9JQ

Customer: Southampton City Council

Date: 17th August 2011

System Type and Location: Cold Water Storage Tank – Tank Room

Disinfecting Product: Sodium Hypochlorite

Contact Time: (hours) Chemical Level @ Start = 58ppm
Chemical Level @ 10 mins = 54ppm
Chemical Level@ Finish – As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk

