



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Hampton Towers  
International Way  
Southampton

**Customer:** Southampton City Council

**Our Reference:** Mike Carroll

**Date:** 14<sup>th</sup> January 2011

**System Type and Location:** Cold Water Storage Tank 1 – Roof Top

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical Level @ Start = 500ppm  
Chemical Level @ 10 Mins = 500ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Hampton Towers  
International Way  
Southampton

**Customer:** Southampton City Council

**Our Reference:** Mike Carroll

**Date:** 14<sup>th</sup> January 2011

**System Type and Location:** Cold Water Storage Tank 2 – Roof Top

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical Level @ Start = 500ppm  
Chemical Level @ 10 Mins = 500ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Hampton Towers  
International Way  
Southampton

**Customer:** Southampton City Council

**Our Reference:** Mike Carroll

**Date:** 14<sup>th</sup> January 2011

**System Type and Location:** Cold Water Storage Tank 3 – Roof Top

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical Level @ Start = 500ppm  
Chemical Level @ 10 Mins = 500ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION



Freeston Water Treatment Limited  
Unit 1, Lulworth Business Centre  
Nutwood Way, Calmore Industrial Estate  
Totton, Southampton  
Hampshire SO40 3WW  
Tel: 02380 669713 Fax: 02380 663825  
Email [info@freeston.co.uk](mailto:info@freeston.co.uk)  
Web: [www.freeston.co.uk](http://www.freeston.co.uk)

## CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

**Site:** Hampton Towers  
International Way  
Southampton

**Customer:** Southampton City Council

**Our Reference:** Mike Carroll

**Date:** 14<sup>th</sup> January 2011

**System Type and Location:** Cold Water Storage Tank 4 – Roof Top

**Disinfecting Product:** Chlorine Dioxide

**Contact Time: (hours)** Chemical Level @ Start = 500ppm  
Chemical Level @ 10 Mins = 500ppm  
Chemical Level @ Finish = As Mains

**Scope of Work Completed:** ACoP L8

Freeston Water Treatment Limited

.....  
(Authorised Signatory)

[www.freeston.co.uk](http://www.freeston.co.uk)



LEGIONELLA  
CONTROL ASSOCIATION