

## Legionella & water quality control fault sheet

Property/site

Reported to

Asset/equipment & description

Asset/equipment code/no

Competent person's description of fault & any action taken

MAIN BOILER LOW TEMP AT  
48°C  
INCREASE TO MIN 60°C

Competent person's signature   
Date

Print name  Organisation

Southampton City Council authorised person's instructions for further action

Southampton City Council authorised person's name and signature   
Date

Corrective action taken by Competent contractor

Competent contractors signature   
Date

Print name  Organisation

Southampton City Council Competent person's verification of action taken   
Date