



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION OF COLD WATER STORAGE TANKS AND DOWNSERVICES

This is to certify that the following water services have been cleaned and disinfected in accordance with ACoP L8 2013/HSG274

Name Southampton Football Club

Address St Marys
Southampton
Hampshire

Date: Jun 03, 2020 13:00

Tank Type and Location: Fan Zone tank

Disinfecting Product: Sanosil Super 25

Contact Time: Chemical Level @ Start = 150+ppm
Chemical Level @ 30 minutes = 150+ppm
Chemical Level @ 60 minutes = 150+ppm
Chemical Level @ Finish = As Mains
Chlorine Level at outlets = refer to FWT409-7

Scope of Work Completed: In Accordance with Method Statement

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeston.co.uk

