

CERTIFICATE OF ANALYSIS

Sender: Freeston Water Treatment Ltd
Unit 1, Lulworth Business Centre
Nutwood Way
Totton, Southampton SO40 3WW

Date Sampled: 07/08/2020
Date Testing Commenced: 08/08/2020
Time Testing Commenced: 08:47
Sample Details: JE 7.8.1

Sample Reference	Time Sampled	Test	Results	Units
Main Pool	10:10	Total Aerobic Colony Count 22°C 3 Days	4	cfu/ml
		Total Aerobic Colony Count 30°C 2 Days	0	cfu/ml
		Total Coliforms	0	cfu/100ml
		Escherichia coli	0	cfu/100ml
		Pseudomonas Aeruginosa	0	cfu/100ml
Cold Pool	10:10	Total Aerobic Colony Count 22°C 3 Days	0	cfu/ml
		Total Aerobic Colony Count 30°C 2 Days	0	cfu/ml
		Total Coliforms	0	cfu/100ml
		Escherichia coli	0	cfu/100ml
		Pseudomonas Aeruginosa	0	cfu/100ml
Hot Pool	10:10	Total Aerobic Colony Count 22°C 3 Days	3	cfu/ml
		Total Aerobic Colony Count 30°C 2 Days	3	cfu/ml
		Total Coliforms	0	cfu/100ml
		Escherichia coli	0	cfu/100ml
		Pseudomonas Aeruginosa	0	cfu/100ml

The above analysis has been carried out for Freeston Water Treatment Limited
by an Independent UKAS Accredited Laboratory (Reg. No. 9658)

DATE ISSUED: 12th August 2020
