

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
12/12/12	Old school building– Cleaners Room	41.2	9.0	-	PS
12/12/12	Old school building – deputy head	40.3	7.2	-	PS
12/12/12	Scola ground floor Staff / visitors wc	51.0	14.2	-	PS
12/12/12	Scola – Staff Kitchen	59.1	13.1	-	PS
12/12/12	Science Room 19	53.5	14.6		PS
12/12/12	Maths block office Mains water		10.4		PS
12/12/12	Maths & Science Block left classroom		12.7		PS
12/12/12	Sports Hall/ badminton building G/F Disabled Toilet	60.6	12.6	41.3	PS
12/12/12	Sports Hall/ badminton building F/F Disabled Toilet	58.6	14.9	41.3	PS
12/12/12	Rothely F/F Bathroom		11.9	41.2	PS
12/12/12	Rothely First floor senior toilet	53.8	9.8	-	PS
12/12/12	Rothely G/F Ladies Toilet	53.5	9.7		PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C