

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
13/11/12	Old school building – staff toilet	51.0	10.6	-	PS
13/11/12	Old school building – deputy head	42.0	11.7	-	PS
13/11/12	Old school building Reception area cleaners room	42.2	11.4		PS
13/11/12	Scola ground floor Junior girls wc	32	17.40	-	PS
13/11/12	Scola – CDT Lobby	21.6	20.5	-	PS
13/11/12	Science block Room 21	55.4	13.0		PS
13/11/12	Maths Office		13.1		
13/11/12	Maths & Science Block left classroom		12.9		PS
13/11/12	Sports Hall/ badminton building disabled toilet	70.0	13.4	41.5	PS
13/11/12	Rothely First floor senior toilet	65.3	10.3	-	PS
13/11/12	Rothely shower room		11.0	42.6	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C