

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
18/10/12	Old school building– medical room	42.0	16.0	-	PS
18/10/12	Old school building – deputy head	43.0	16.0	-	PS
18/10/12	Scola ground floor Junior girls wc	51.0	19.0	-	PS
18/10/12	Scola – male wc	53.0	27.0	-	PS
18/10/12	Maths block office Mains water		19.0		PS
18/10/12	Maths & Science Block left classroom		18.0		PS
18/10/12	Sports Hall/ badminton building	62.0	28.0	41.0	PS
18/10/12	Rothely Laundry	67.6	13.3		PS
18/10/12	Rothely First floor senior toilet	63.4	11.9	-	PS
18/10/12	Rothely shower room		17.0	43.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C



FREESTON

Water Treatment