

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
20/09/12	Old school block – girls wc	No hot	15.0	-	Kg
20/09/12	Old school block – deputy head	45.8	14.9	-	Kg
20/09/12	Main kitchen	34.0	15.6	-	Kg
20/09/12	Scola – male wc	51.0	20	-	Kg
20/09/12	Maths block – mains	-	-	18	Kg
20/09/12	Baby cottage – wc	51.0	18.0	-	Kg
20/09/12	Rotherly – ground floor room 3	51.0	17.8	-	Kg
20/09/12	Rotherly – 1 st floor wc opposite rm 5	51.6	16.8	-	

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C