

7. Hot Water Calorifier Flow & Return Temperature Record

Year: 2013

Hot water calorifier no. 1 Sadia hot water heater

Location: Site maintenance office

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	43											
Return °C	36											
Stored °C	-											
Initial	KG											

Year: 2013

Hot water calorifier no.2 State hot water heater 220lts (2)

Location: kitchen (external boiler house)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	60											
Return °C	51											
Stored °C	-											
Initial	KG											

Year: 2013

Hot water calorifier no.3 State hot water heater 220lts (1)

Location: kitchen (external boiler house)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	61											
Return °C	51											
Stored °C	-											
Initial	KG											

Note: Record temperatures (°C).
 Note any that fall outside 60°C (flow) and 50°C (return) as an out of tolerance and take appropriate action.

Year: 2013
 Hot water calorifier no. 4 Sadia hot water heater 15lts
 Location: roof space above reception (old school building)
 *outlet temperature at tea point

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	*58											
Return °C	-											
Stored °C	-											
Initial	KG											

Year: 2013
 Hot water calorifier no. 5 Hot water heater
 Location: cleaner's cupboard (old school building)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	63											
Return °C	-											
Stored °C	-											
Initial	KG											

Year: 2013
 Hot water calorifier no. 6 Instantaneous electric hot water heater
 Location: staff wc (old school building)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	39*											
Return °C	-											
Stored °C	-											
Initial	KG											

*outlet temperature

Year: 2013

Hot water calorifier no. 10 (1)

Location: sports hall / badminton plant room

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	51											
Return °C	53											
Stored °C	-											
Initial	KG											

Year: 2013

Hot water calorifier no. 11 (2)

Location: sports hall / badminton plant room

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	71											
Return °C	53											
Stored °C	-											
Initial	KG											

Year: 2013

Hot water calorifier no. 12 combination boiler

Location: baby cottage - external 'shed'

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	55*											
Return °C	-											
Stored °C	-											
Initial	KG											

*outlet temperature

