

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
05/11/2013	Old school building – deputy head	56.5	12.5	-	PS
05/11/2013	Old school building – Boys Toilet	55.4	11.8		
05/11/2013	Old school building – Girls Toilet	50.5	11.7		PS
05/11/2013	Scola science room 21 –	57.8	12.9	-	PS
05/11/2013	Scola staff room kitchen	65.0	18.7		PS
05/11/2013	Scola staff / visitor Toilet	55.4	17.6		PS
05/11/2013	Scola CDT Toilet	65.4	19.0	42.1	PS
05/11/2013	Scola Senior Girls Toilet			38.5	
05/11/2013	Maths block office - Mains water		14.4	-	PS
05/11/2013	Sports Hall/ badminton building – lower ground staff wc	55.0	17.5	39.3	PS
05/11/2013	Sports Hall/ badminton building –ground floor cleaners room	64.0	17.3	42.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C