

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
08/04/2013	Old school building – deputy head	51.0	8.6	-	PS
08/04/2013	Old school building – Boys Toilet	48.4	8.6	-	PS
08/04/2013	Old school building – Staff Toilet	51.0	8.7		PS
08/04/2013	Scola science room 21 –	59.5	10.6	-	PS
08/04/2013	Scola staff room kitchen	62.4	14.2		PS
08/04/2013	Scola staff visitors toilet	55.0	16.3		PS
08/04/2013	Scola art room 34	57.0	17.8		PS
08/04/2013	Maths block office - Mains water	-	11.1	-	PS
08/04/2013	Sports Hall/ badminton building – ground floor disabled wc	61.4	24.2	39.7	PS
08/04/2013	Sports Hall/ badminton building – lower ground floor staff toilet	61.0	13.3	37.4	PS
08/04/2013	Rothely – ground floor laundry	55.0	12.7	-	PS
08/04/2013	Rothely – ground floor ladies WC	54.1	10.0		PS
08/04/2013	Rothely – ground floor Room 1	53.4	13.7		
08/04/2013	Rothely - 1 st floor room senior toilet	55.0	10.1	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C