

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
05/08/2013	Old school building – deputy head	56.1	17.7	-	PS
05/08/2013	Old school building – staff Toilet	57.6	18.5		PS
05/08/2013	Old school building – Boys Toilet	47.6	17.6		PS
05/08/2013	Old school building – Girls Toilet	21.0	17.5		PS
05/08/2013	Scola science room 21 –	58.2	19.0	-	PS
05/08/2013	Scola staff room kitchen	62.5	20.5		PS
05/08/2013	Scola Gents Toilet	52.0	23.3		PS
05/08/2013	Scola Junior Girls Toilet	50.0	24.0	37.4	PS
05/08/2013	Scola CDT Toilet	23.0	23.0		PS
05/08/2013	Maths block office - Mains water		17.5	-	PS
05/08/2013	Sports Hall/ badminton building – lower ground floor disabled wc	60.5	20.9	45.0	PS
05/08/2013	Sports Hall/ badminton building – ground floor disabled wc	55.0	23.2	42.0	PS
05/08/2013	Rothely – ground floor laundry	62.6	16.1	-	PS
05/08/2013	Rothely - ground floor ladies wc	61.6	18.0	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C