

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
02/12/2013	Old school building– deputy head	57.1	9.9	-	PS
02/12/2013	Old school building – staff WC	51.8	12.4		PS
02/12/2013	Old school building – Boys WC	53.6	11.5		PS
02/12/2013	Scola science room 21 –	59.2	10.6	-	PS
02/12/2013	Scola staff room kitchen	63.5	16.8		PS
02/12/2013	Scola Art Room 32	59.1	21.5	38.3	PS
02/12/2013	Scola CDT Toilet	63.4	23.3	41.7	PS
02/12/2013	Scola staff & visitors WC	50.0	21.2		
02/12/2013	Maths block office - Mains water		13.3	-	PS
02/12/2013	Science left classroom		10.8		PS
02/12/2013	Main kitchen	56.1	9.9		PS
02/12/2013	Sports Hall/ badminton building – lower ground disabled WC	54.5	11.9	38.3	PS
02/12/2013	Sports Hall/ badminton building –first floor disabled WC	54.3	10.9	40.5	PS
02/12/2013	Rothely New Nursery kitchen	54.2	10.3		PS
02/12/2013	Rothely New Nursery Pre-school classroom	54.5	11.6	38.9	PS
02/12/2013	Rothely New Nursery Toddlers WC	55.2	10.7	38.3	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C