

## 9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
02/07/2013	Old school building – deputy head	51.2	15.2	-	PS
02/07/2013	Old school building – Boys Toilet	48.6	14.8		PS
02/07/2013	Old school building – Cleaners Cupboard	50.0	14.8		PS
02/07/2013	Scola science room 21 –	56.2	17.4	-	PS
02/07/2013	Scola staff room kitchen	63.1	17.6		PS
02/07/2013	Scola saff & visitors wc	50.0	18.5		PS
02/07/2013	Scola Boys wc	51.0	21.8	39.0	
02/07/2013	Scola CDT Toilet	22.0	22.9		PS
02/07/2013	Maths block office - Mains water		14.5	-	PS
02/07/2013	Sports Hall/ badminton building – lower ground floor disabled wc	57.8	19.7	43.3	PS
02/07/2013	Sports Hall/ badminton building – ground floor disabled wc	58.7	23.5	42.2	PS
02/07/2013	Rothely – ground floor laundry	62.1	14.9	-	PS
02/07/2013	Rothely – ground floor Room 6	61.0			PS
02/07/2013	Rothely - ground floor ladies wc	61.9	15.4	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C