

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
04/06/2013	Old school building– deputy head	19.5	13.5	-	PS
04/06/2013	Old school building – Staff Toilet	53.1	15.7		PS
04/06/2013	Scola science room 21 –	57.5	13.8	-	PS
04/06/2013	Scola staff room kitchen	62.1	16.8		PS
04/06/2013	Scola saff & visitors wc	50.5	17.6		PS
04/06/2013	Scola CDT Toilet	20.0	18.8		PS
04/06/2013	Maths block office - Mains water		12.5	-	PS
04/06/2013	Sports Hall/ badminton building – ground floor disabled wc	62.0	18.6	43.9	PS
04/06/2013	Science block left hand classroom		12.8		PS
04/06/2013	Sports Hall/ badminton building – lower ground floor staff toilet	58.0	20.6	41.1	PS
04/06/2013	Sports Hall/ badminton building – first floor toilet	52.3	20.3	37.3	PS
04/06/2013	Rothely – ground floor laundry	55.2	13.4	-	PS
04/06/2013	Rothely – first floor Room 4	55.8	13.1		PS
04/06/2013	Rothely - 1 st floor room senior toilet	55.3	13.3	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C