

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
05/02/2013	Old school building – deputy head	51.0	8.4	-	PS
05/02/2013	Old school building – Boys Toilet	47.0	8.6	-	PS
05/02/2013	Scola science room 21 –	56.5	8.9	-	PS
05/02/2013	Scola staff room kitchen	61.2	12.7		PS
05/02/2013	Scola staff visitors toilet	54.0	13.8		PS
05/02/2013	Maths block office - Mains water	-	9.9	-	PS
05/02/2013	Maths & Science Block - left classroom	-	14.7	-	PS
05/02/2013	Sports Hall/ badminton building – ground floor disabled wc	64.0	12.2	40.0	PS
05/02/2013	Sports Hall/ badminton building – lower ground floor staff toilet	65.0	9.9	39.0	PS
05/02/2013	Rothely – ground floor laundry	55.0	14.5	-	PS
05/02/2013	Rothely - 1 st floor room senior toilet	54.4	9.7	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C