

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
07/05/2013	Old school building – deputy head	24.8	14.8	-	PS
07/05/2013	Old school building – Staff Toilet	57.5	15.1		PS
07/05/2013	Scola science room 21 –	56.8	14.1	-	PS
07/05/2013	Scola staff room kitchen	63.1	16.1		PS
07/05/2013	Scola art room 32	60.1	18.3		PS
07/05/2013	Scola CDT Toilet	19.4	19.6		PS
07/05/2013	Scola CDT Sink	19.3	22.1		PS
07/05/2013	Maths block office - Mains water		12.4	-	PS
07/05/2013	Sports Hall/ badminton building – ground floor disabled wc	62.0	18.6	43.9	PS
07/05/2013	Sports Hall/ badminton building – lower ground floor staff toilet	58.8	17.3	39.9	PS
07/05/2013	Sports Hall/ badminton building – lower ground floor disabled toilet	60.4	17.1	41.8	PS
07/05/2013	Rothely – ground floor laundry	48.8	14.8	-	PS
07/05/2013	Rothely – ground floor Room 1	51.8	15.3		PS
07/05/2013	Rothely - 1 st floor room senior toilet	51.3	12.1	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C