

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
01/10/2013	Old school building– deputy head	52.6	16.4	-	PS
01/10/2013	Old school building – staff Toilet	56.2	16.5		PS
01/10/2013	Old school building – Girls Toilet	50.0	16.2		PS
01/10/2013	Scola science room 21 –	55.9	15.9	-	PS
01/10/2013	Scola staff room kitchen	60.4	18.9		PS
01/10/2013	Scola staff / visitor Toilet	53.0	19.7		PS
01/10/2013	Scola CDT Toilet	71.0	21.1	41.6	PS
01/10/2013	Maths block office - Mains water		15.4	-	PS
01/10/2013	Sports Hall/ badminton building – lower ground disabled wc	62.5	17.6	41.5	PS
01/10/2013	Sports Hall/ badminton building –ground floor cleaners room	70.6	18.2	42.0	PS
01/10/2013	Sports Hall/ badminton building –ground floor disabled wc	58.5	18.9	41.6	PS
01/10/2013	Rothely – ground floor laundry	63.0	15.6	-	PS
01/10/2013	Rothely – ground floor room 2	60.6	19.0		PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C