

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
02/09/2013	Old school building – deputy head	53.2	17.5	-	PS
02/09/2013	Old school building – staff Toilet	53.7			PS
02/09/2013	Old school building – Boys Toilet	54.0	17.4		PS
02/09/2013	Old school building – Disabled Toilet		17.5		PS
02/09/2013	Scola science room 21 –	55.4	16.2	-	PS
02/09/2013	Scola staff room kitchen	61.0	20.3		PS
02/09/2013	Scola staff / visitor Toilet	53.2	22.3		PS
02/09/2013	Scola art room 32	54.0	22.0	37.3	PS
02/09/2013	Scola CDT Toilet	66.0	21.3	41.5	PS
02/09/2013	Maths block office - Mains water		16.9	-	PS
02/09/2013	Sports Hall/ badminton building – lower ground staff wc	63.5	18.1	39.8	PS
02/09/2013	Sports Hall/ badminton building –ground floor wc	51.0	18.1	42.0	PS
02/09/2013	Rothely – ground floor laundry	64.3	16.7	-	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C