

10.Cold Water Storage Tank Temperatures & Condition Record

Date	Tank I.D	Stored Temp	Mains Temp	Sludge – clean/light/medium/heavy	Initial
29 th October 2013	Old School Building Humanities Stairwell Tank	15.0°C	15.0°C	Cleaned & Disinfected	PS
29 th October 2013	Old School Building Roof Void Front Tank	17.0°C	15.0°C	Cleaned & Disinfected	PS
29 th October 2013	Old School Building Roof Void Rear Tank	17.0°C	15.0°C	Cleaned & Disinfected	PS
29 th October 2013	Science Prep Room	17.0°C	15.0°C	Cleaned & Disinfected	PS