



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Westgate School
Cheriton Road
Winchester
SO22 5AZ

Date: 29th October 2013

System Type and Location: Cold Water Storage Tank 1 – Tank above Stairs

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 500ppm
Chemical Level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeston Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeston.co.uk
Web: www.freeston.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Westgate School
Cheriton Road
Winchester
SO22 5AZ

Date: 29th October 2013

System Type and Location: Cold Water Storage Tank 2 – Loft above Rear Doors
To School Linked

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 500ppm
Chemical Level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeston Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:
www.freeston.co.uk



LEGIONELLA
CONTROL ASSOCIATION



Freeton Water Treatment Limited
Unit 1, Lulworth Business Centre
Nutwood Way, Calmore Industrial Estate
Totton, Southampton
Hampshire SO40 3WW
Tel: 02380 669713 Fax: 02380 663825
Email info@freeton.co.uk
Web: www.freeton.co.uk

CERTIFICATE OF CLEANING AND DISINFECTION

This is to certify that the following water services have been disinfected in accordance with ACoP L8 2001

Site: The Westgate School
Cheriton Road
Winchester
SO22 5AZ

Date: 29th October 2013

System Type and Location: Cold Water Storage Tank 2 – Loft Space above Rear
Door to School Linked

Disinfecting Product: Chlorine Dioxide

Contact Time: Chemical Level @ Start \geq 500ppm
Chemical Level @ 10 minutes \geq 500ppm
Chemical Level @ Finish = As Mains

Scope of Work Completed: ACoP L8

Freeton Water Treatment Limited

.....
(Authorised Signatory)

We value customer feedback and would appreciate your comments:

www.freeton.co.uk



LEGIONELLA
CONTROL ASSOCIATION