

6 Out of Tolerance Result and Action Record

Date	Record No.	System / Location	Type of Out of Tolerance
01/08/2014	0126	Old school building cleaners room water heater	Hot water is not stored at 60.0c and has been below this for several months.
01/08/2014	0127	CDT toilet area Scola block food tech, & art room 34. Science block right hand classroom.	Elevated cold water temperatures.
01/08/2014	0128	Sports / Badminton Block First aid room.	No access to outlets for monthly monitoring due to tables being stored.

Record No.	Action Required	Action Completed	Signature
0126	Adjust water heater thermostat to store hot water at 60.0c.		
0127	Ensure these areas are included in weekly flushing; and pipe runs are insulated to help prevent heat gain on cold water pipe runs.		
0128	Clear room so access can be made to water outlets for monthly monitoring and flushing can be carried out.		

Continue with weekly flushing of infrequently used outlets and record when carried out.