

6 Out of Tolerance Result and Action Record

Date	Record No.	System / Location	Type of Out of Tolerance
04/02/2014	0109	Old School Building Calorifier	Low storage temperature.
04/02/2014	0110	Rothely Nursery Building Calorifier	Low storage temperature
04/02/2014	0111	Sports Hall No.2 Calorifier	Low storage temperature

Record No.	Action Required	Action Completed	Signature
0109	Adjust Old School Building calorifier to store hot water at 60.0c.		
0110	Adjust Rothely Nursery Building calorifier to store hot water at 60.0c.		
0111	Adjust Sports Hall No.2 calorifier to store hot water at 60.0c.		

Continue with weekly flushing of infrequently used outlets and record when carried out.