

6 Out of Tolerance Result and Action Record

Date	Record No.	System / Location	Type of Out of Tolerance
02/01/2014	0105	Sports Hall Calorifier	No.1 calorifier very high storage temperature..
02/01/2014	0106	Scola Building cold water system.	Elevated cold water at most outlets.
02/01/2014	0107	Main kitchen	No.1 calorifier low storage temperature
02/01/2014	0108	Main kitchen	Low return temperature to both hot water calorifiers

Record No.	Action Required	Action Completed	Signature
0105	Adjust sports hall No.1 calorifier to store hot water at 60.0c.		
0106	Flush cold water outlets before school returns from xmas holiday		
0107	Adjust main kitchen No.1 calorifier to store hot water at 60.0c.		
0108	Investigate return pump for correct operation and achieve 50.0c or more on the return to both calorifiers.		

Continue with weekly flushing of infrequently used outlets and record when carried out.