

## 6 Out of Tolerance Result and Action Record

Date	Record No.	System / Location	Type of Out of Tolerance
01/05/2014	0120	Old School Building Hot Water Calorifier	Storage and return temperatures were found to be low again at the time of monitoring being carried out.
01/05/2014	0121	CDT cold water	Elevated cold water temperatures.

Record No.	Action Required	Action Completed	Signature
0120	<p>Adjust Old School Building calorifier to store hot water at 60.0c and maintain 50.0c or more on the return; investigate system for correct operation and ideally left on.</p> <p><u>I would recommend Legionella water sampling be carried out on this hot water system as it has been at low temperatures for several months.</u></p>		
0121	<p>Ensure CDT area is included in weekly flushing; and pipe runs are insulated to help prevent heat gain on cold water pipe runs.</p>		

Continue with weekly flushing of infrequently used outlets and record when carried out.