

6 Out of Tolerance Result and Action Record

Date	Record No.	System / Location	Type of Out of Tolerance
07/11/2014	0136	Hot water system in Scola Block	Hot water did not achieve 50.0c within one minute in the staff & visitors toilet. Hot water did not achieve 50.0c within one minute in science classrooms 17 & 20.
07/11/2014	0137	CDT toilet area Scola block disabled toilet.	Elevated cold water temperatures. Disabled toilet has poor cold flow.
07/11/2014	0138	Hot water system badminton Block	No.2 calorifier storage temperature found to be below the recommended 60.0c.

Record No.	Action Required	Action Completed	Signature
0136	Investigate hot water system to staff and visitor's toilet areas and science rooms 17 & 20; ensure system opened up correctly.		
0137	Ensure these areas are included in weekly flushing; and pipe runs are insulated to help prevent heat gain on cold water pipe runs. Investigate poor cold flow from disabled toilet outlet.		
0138	Raise No.2 hot water calorifier storage temperature to 60.0c.		

Continue with weekly flushing of infrequently used outlets and record when carried out.