

6 Out of Tolerance Result and Action Record

Date	Record No.	System / Location	Type of Out of Tolerance
03/10/2014	0133	Hot water system in Nursery	Hot water had low storage and return temperatures at time of monthly monitoring; calorifier had an error code on the front panel; E02.
03/10/2014	0134	CDT toilet area. Scola block disabled toilet and gent's toilet. Science block right hand classroom.	Elevated cold water temperatures. Poor water flow.
03/10/2014	0135	Hot water system Old School Building girls toilet	Hot water did not achieve 50.0c at the outlets within one minute.

Record No.	Action Required	Action Completed	Signature
0133	Investigate fault with nursery hot water calorifier and ensure system stores hot water at 60.0c and the return maintains 50.0c or more.		
0134	Ensure these areas are included in weekly flushing; and pipe runs are insulated to help prevent heat gain on cold water pipe runs. Ensure there is a good flow of water at all outlets within the toilet areas.		
0135	Investigate hot water system to toilet outlets ensure system opened up correctly.		

Continue with weekly flushing of infrequently used outlets and record when carried out.