

## 7. Hot Water Calorifier Flow & Return Temperature Record

Year: 2014

Hot water calorifier no. 1 Sadia hot water Calorifier

Location: Site maintenance office

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	62.4	41.0										
Return °C	54.3	39.4										
Stored °C												
Initial	PS	PS										

Year: 2014

Hot water calorifier no.2 State hot water heater 220lts (2)

Location: kitchen (external boiler house)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	58.9	62.7										
Return °C	45.5	59.4										
Stored °C												
Initial	PS	PS										

Year: 2014

Hot water calorifier no.3 State hot water heater 220lts (1)

Location: kitchen (external boiler house)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	56.0	73.1										
Return °C	45.5	59.4										
Stored °C												
Initial	PS	PS										

Note: Record temperatures (°C).

Note any that fall outside 60°C (flow) and 50°C (return) as an out of tolerance and take appropriate action.



Year: 2014

Hot water calorifier no. 8 AO Smith hot water calorifier 278lts

Location: Scola boilerhouse

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	67.5	65.2										
Return °C	62.6	62.5										
Stored °C												
Initial	PS	PS										

Year: 2014

Hot water calorifier no. 9 hot water calorifier 270lts

Location: gym plant room

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	64.1	63.7										
Return °C	59.5	59.2										
Stored °C												
Initial	PS	PS										

FREESTON  
Water Treatment



