

## 7. Hot Water Calorifier Flow & Return Temperature Record

Year: 2014

Hot water calorifier no. 1 Sadia hot water Calorifier

Location: Site maintenance office

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	62.4											
Return °C	54.3											
Stored °C												
Initial	PS											

Year: 2014

Hot water calorifier no.2 State hot water heater 220lts (2)

Location: kitchen (external boiler house)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	58.9											
Return °C	45.5											
Stored °C												
Initial	PS											

Year: 2014

Hot water calorifier no.3 State hot water heater 220lts (1)

Location: kitchen (external boiler house)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	56.0											
Return °C	45.5											
Stored °C												
Initial	PS											

Note: Record temperatures (°C).

Note any that fall outside 60°C (flow) and 50°C (return) as an out of tolerance and take appropriate action.



Year: 2014

Hot water calorifier no. 8 AO Smith hot water calorifier 278lts

Location: Scola boilerhouse

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	67.5											
Return °C	62.6											
Stored °C												
Initial	PS											

Year: 2014

Hot water calorifier no. 9 hot water calorifier 270lts

Location: gym plant room

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Flow °C	64.1											
Return °C	59.5											
Stored °C												
Initial	PS											

FREESTON  
Water Treatment



