

7. Hot Water Calorifier Flow & Return Temperature Record

Year: 2014

Hot water calorifier no. 1 Sadia hot water Calorifier

Location: Site maintenance office

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|------|------|------|------|------|------|------|------|------|------|------|-----|
| Flow °C | 62.4 | 41.0 | 42.5 | 21.0 | 21.9 | 65.5 | 60.0 | 63.6 | 60.5 | 60.0 | 60.0 | |
| Return °C | 54.3 | 39.4 | 38.0 | 20.0 | 21.4 | 54.1 | 55.0 | 60.6 | 56.5 | 56.5 | 56.0 | |
| Stored °C | | | | | | | | | | | | |
| Initial | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | |

Year: 2014

Hot water calorifier no.2 State hot water heater 220lts (2)

Location: kitchen (external boiler house)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|------|------|------|------|------|------|------|------|------|------|------|-----|
| Flow °C | 58.9 | 62.7 | 68.3 | 64.5 | 56.0 | 37.5 | 64.8 | 63.1 | 69.0 | 74.8 | 68.0 | |
| Return °C | 45.5 | 59.4 | 60.4 | 54.0 | 54.3 | 52.8 | 57.8 | 53.0 | 60.0 | 52.0 | 53.0 | |
| Stored °C | | | | | | | | | | | | |
| Initial | PS | PS | PS | PS | PS | PS | PS | | PS | PS | PS | |

Year: 2014

Hot water calorifier no.3 State hot water heater 220lts (1)

Location: kitchen (external boiler house)

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|------|------|------|------|------|------|------|------|------|------|------|-----|
| Flow °C | 56.0 | 73.1 | 74.0 | 64.7 | 66.7 | 66.8 | 63.5 | 73.2 | 72.0 | 72.4 | 60.0 | |
| Return °C | 45.5 | 59.4 | 60.4 | 54.0 | 54.3 | 52.8 | 57.8 | 60.0 | 60.0 | 52.0 | 53.0 | |
| Stored °C | | | | | | | | | | | | |
| Initial | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | |

Note: Record temperatures (°C).

Note any that fall outside 60°C (flow) and 50°C (return) as an out of tolerance and take appropriate action.

Year: 2014

Hot water calorifier no. 16 Sadia hot water heater 25lts

Location: science & maths – right hand classroom

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|------|------|------|------|------|------|------|------|------|------|------|-----|
| Flow °C | 66.2 | 71.4 | 67.6 | 66.3 | 65.9 | 67.5 | 66.2 | 68.0 | 66.5 | 67.5 | 66.4 | |
| Return °C | | | | | | | | | | | | |
| Stored °C | | | | | | | | | | | | |
| Initial | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | |

Year: 2014

Hot water calorifier no. 18 hot water calorifier)

Location: Rotherly New Nursery Building Boiler Room

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|-----------|------|------|------|------|------|------|------|------|------|------|------|-----|
| Flow °C | 60.0 | 56.5 | 60.0 | 61.8 | 64.2 | 63.5 | 62.0 | 60.0 | 64.1 | 31.0 | 63.0 | |
| Return °C | 50.0 | 50.2 | 50.0 | 52.7 | 55.0 | 57.0 | 54.0 | 52.0 | 55.1 | 30.3 | 54.0 | |
| Stored °C | | | | | | | | | | | | |
| Initial | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | PS | |

FREESTON
Water Treatment