

8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	Visitors female wc	41.0	9.8	-	No	PS
04/02/2014	Cleaners Cupboard	41.1	11.1		No	PS
04/02/2014	Reception Tea Bay	54.0	9.4	-	Yes	PS
04/02/2014	Caretakers Workshop	40.5	9.4	-	No	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	Food tech room 26	60.6	18.9	-	Yes	PS
04/02/2014	Art room 33 – main block 2 nd floor	68.5	16.6	-	Yes	PS
04/02/2014	Room 20 - Science block	56.7	12.3	-	Yes	PS
04/02/2014	Disabled changing Room (mixer tap)	60.3	21.5	41.5	No	PS
04/02/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
04/02/2014	Cleaners room	68.1	18.6	-	Yes	PS
04/02/2014	Female staff Room Toilet	68.3	17.0	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	*Ground level - Coffee shop & Kitchen	69.3	8.2	-	Yes	PS
04/02/2014	Lower level – Cleaners room	68.2	8.8	-	Yes	PS
04/02/2014	Lower level – 1 st aid room	60.5	8.6	38.5	Yes	PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	Store room	64.2	11.1		Yes	PS
04/02/2014	'right' classroom	71.4	17.5		Yes	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	Kitchen	70.1	7.8	-	Yes	PS

Date	Location –New Rothely Nursery Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/02/2014	Staff Room	56.5	9.2		Yes	PS
04/02/2014	Changing Room	51.6	9.2		Yes	PS
04/02/2014	Pre-School WC	53.5	9.2	38.0	Yes	PS

