

## 8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
02/01/2014	Visitors female wc	55.0	9.4	-	Yes	PS
02/01/2014	Cleaners Cupboard	No Access				
02/01/2014	Reception Tea Bay	59.5	9.5	-	Yes	PS
02/01/2014	Caretakers Workshop	58.8	9.3	-	Yes	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
02/01/2014	Food tech room 26	60.5	27.0	-	No	PS
02/01/2014	Art room 33 – main block 2 <sup>nd</sup> floor	67.5	23.7	-	No	PS
02/01/2014	Room 20 - Science block	62.5	13.5	-	Yes	PS
02/01/2014	Disabled changing Room (mixer tap)	59.5	23.8	42.1	No	PS
02/01/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
02/01/2014	Cleaners room	67.1	26.4	-	No	PS
02/01/2014	Female staff Room Toilet	6.7	19.4	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
02/01/2014	*Ground level - Coffee shop & Kitchen	72.7	12.9	-	Yes	PS
02/01/2014	Lower level – Cleaners room	76.4	12.9	-	Yes	PS
02/01/2014	Lower level – 1 <sup>st</sup> aid room	68.2	13.3	40.0	yes	PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
02/01/2014	Store room	63.5	12.4		Yes	PS
02/01/2014	'right' classroom	66.2	19.1		Yes	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
02/01/2014	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
02/01/2014	Kitchen	54.0	8.1	-	Yes	PS

<b>Date</b>	<b>Location –New Rothely Nursery Building</b>	<b>Hot °C</b>	<b>Cold °C</b>	<b>TMV °C</b>	<b>Temperature satisfactory</b>	<b>Initial</b>
02/01/2014	Staff Room	53.2	9.3		Yes	PS
02/01/2014	Changing Room	55.6	9.2		Yes	PS
02/01/2014	Pre-School WC	55.4	9.2	38.3	Yes	PS

