

8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	Visitors female wc	52.8	17.0	-	Yes	PS
03/07/2014	Cleaners Cupboard	57.3	16.1		Yes	PS
03/07/2014	Reception Tea Bay	54.8	16.3	-	Yes	PS
03/07/2014	Caretakers Workshop	59.3	16.1	-	Yes	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	Food tech room 26	60.3	18.8	-	Yes	PS
03/07/2014	Art room 33 – main block 2 nd floor	68.0	17.5	-	Yes	PS
03/07/2014	Room 20 - Science block	57.1	16.9	-	Yes	PS
03/07/2014	Disabled changing Room (mixer tap)	58.5	24.2	41.6	No	PS
03/07/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
03/07/2014	Cleaners room	66.5	18.7		Yes	PS
03/07/2014	Female staff Room Toilet	68.3	17.3	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	*Ground level - Coffee shop & Kitchen	68.1	16.7	-	Yes	PS
03/07/2014	Lower level – Cleaners room	68.3	16.7	-	Yes	PS
03/07/2014	Lower level – 1 st aid room	No Access Exams	No Access Exams			PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	Store room	64.9	19.6		Yes	PS
03/07/2014	'right' classroom	66.2	22.2		No	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	Kitchen	67.2	17.4	-	Yes	PS

Date	Location –New Rothely Nursery Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
03/07/2014	Staff Room	57.2	16.3		Yes	PS
03/07/2014	Changing Room	59.2	16.4		Yes	PS
03/07/2014	Pre-School WC	60.5	17.4	37.2	Yes	PS

