

## 8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/06/2014	Visitors female wc	58.7	14.6	-	Yes	PS
04/06/2014	Cleaners Cupboard	37.2	14.7		No	PS
04/06/2014	Reception Tea Bay	56.5	14.3	-	Yes	PS
04/06/2014	Caretakers Workshop	64.1	14.3	-	Yes	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/06/2014	Food tech room 26	61.2	19.5	-	Yes	PS
04/06/2014	Art room 33 – main block 2 <sup>nd</sup> floor	67.6	15.8	-	Yes	PS
04/06/2014	Room 20 - Science block	59.0	15.0	-	Yes	PS
04/06/2014	Disabled changing Room (mixer tap)	58.0	20.5	40.8	No	PS
04/06/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
04/06/2014	Cleaners room	67.5	18.5		Yes	PS
04/06/2014	Female staff Room Toilet	67.2	16.3	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/06/2014	*Ground level - Coffee shop & Kitchen	68.3	15.2	-	Yes	PS
04/06/2014	Lower level – Cleaners room	69.4	15.4	-	Yes	PS
04/06/2014	Lower level – 1 <sup>st</sup> aid room	64.5	15.6	40.9	Yes	PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/06/2014	Store room	64.2	18.8		Yes	PS
04/06/2014	'right' classroom	67.5	20.6		No	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/06/2014	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/06/2014	Kitchen	63.2	15.5	-	Yes	PS

<b>Date</b>	<b>Location –New Rothely Nursery Building</b>	<b>Hot °C</b>	<b>Cold °C</b>	<b>TMV °C</b>	<b>Temperature satisfactory</b>	<b>Initial</b>
01/05/2014	Staff Room	58.4	14.6		Yes	PS
01/05/2014	Changing Room	61.7	14.8		Yes	PS
01/05/2014	Pre-School WC	63.4	14.9	39.1	Yes	PS

