

## 8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/03/2014	Visitors female wc	40.2	8.7	-	No	PS
04/03/2014	Cleaners Cupboard	40.9	9.3		No	PS
04/03/2014	Reception Tea Bay	54.8	9.3	-	Yes	PS
04/03/2014	Caretakers Workshop	42.2	9.1	-	No	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/03/2014	Food tech room 26	60.0	17.9	-	Yes	PS
04/03/2014	Art room 33 – main block 2 <sup>nd</sup> floor	67.7	16.8	-	Yes	PS
04/03/2014	Room 20 - Science block	61.6	11.8	-	Yes	PS
04/03/2014	Disabled changing Room (mixer tap)	59.3	21.0	41.6	No	PS
04/03/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
04/03/2014	Cleaners room	68.1	17.1	-	Yes	PS
04/03/2014	Female staff Room Toilet	67.5	15.5	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/03/2014	*Ground level - Coffee shop & Kitchen	71.0	10.5	-	Yes	PS
04/03/2014	Lower level – Cleaners room	73.5	9.8	-	Yes	PS
04/03/2014	Lower level – 1 <sup>st</sup> aid room	67.6	10.1	40.0	Yes	PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/03/2014	Store room	66.0	12.4		Yes	PS
04/03/2014	'right' classroom	67.6	18.7		Yes	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
04/03/2014	Kitchen	69.7	7.8	-	Yes	PS

<b>Date</b>	<b>Location –New Rothely Nursery Building</b>	<b>Hot °C</b>	<b>Cold °C</b>	<b>TMV °C</b>	<b>Temperature satisfactory</b>	<b>Initial</b>
04/03/2014	Staff Room	55.2	9.7		Yes	PS
04/03/2014	Changing Room	56.8	9.4		Yes	PS
04/03/2014	Pre-School WC	56.5	8.4	36.5	Yes	PS

